



# **Operating instruction for SICON.PLUG AI VAC**

SICON-DOC



## Table of Contents

<b>Important Information .....</b>	<b>5</b>
1.1 The technical documentation is a part of the product. ....	5
1.2 Note on Using these Operating Instructions .....	5
<b>Fundamental Safety Instructions .....</b>	<b>6</b>
1. Intended Use .....	6
2. Non-Intended Use .....	6
3. Personnel Qualifications .....	6
4. Signal words in This Document .....	6
5. Environmental and Operating Conditions .....	7
6. Technical Condition: .....	7
7. Operator Responsibilities Regarding Country-Specific Regulations: .....	7
<b>Introduction.....</b>	<b>9</b>
<b>Advantages of your SICON.PLUG AI VAC.....</b>	<b>10</b>
Connection .....	10
Industry 4.0 Ready .....	10
Analytics .....	10
<b>Structure of your SICON.PLUG ANALYTICS VAC.....</b>	<b>11</b>
1.1 Front panel controls .....	11
1.2 Controls on the upper side .....	11
1.3 Controls on the bottom side .....	12
1.4 Status bar .....	13
1.5 Reset Button .....	14
1.6 NFC interface .....	14
1.7 Gyroscope and accelerometer .....	15
<b>Commissioning .....</b>	<b>16</b>
1.8 IT security and port sharing .....	16
1.9 Mounting location .....	16
1.10 Mounting .....	17
1.11 Hosing .....	17
1.12 Electrical connection .....	18
<b>Important functions .....</b>	<b>20</b>
1.13 Resetting SICON.PLUG ANALYTICS VAC to factory settings .....	20
1.14 Calibration of the vacuum sensors .....	20
1.15 Storing a filter reference value in SICON.PLUG ANALYTICS VAC .....	20



1.16 Lock reset button .....	21
1.17 Machine condition level.....	21
<b>Tips and help.....</b>	<b>22</b>
1.18 Technical data.....	22
1.19 CE conformity and disposal of old equipment .....	22
<b>Next steps.....</b>	<b>23</b>



### Note

The product information was originally written in German. Please keep a copy of this document for future reference. Technical modifications may occur without prior notice. No liability is assumed for printing or other errors.

### Published by

© GPS GmbH, 02/24

This document is protected by copyright. GPS GmbH retains the rights established therein. Reproduction of the contents, whether in full or in part, is only permissible within the boundaries of the legal provisions of copyright law. Any alterations to or abbreviations of the document are strictly prohibited without explicit written consent from GPS GmbH.

**GPS GmbH** · Nobelstr. 15 · 70569 Stuttgart, Germany · T: +49 711 6870 31 30  
[info@gps-stuttgart.de](mailto:info@gps-stuttgart.de)



---

## Important Information

### 1.1 The technical documentation is a part of the product.

1. Keep the technical documentation near the product for easy access and follow the instructions carefully.
2. Share the technical documentation with subsequent users.

**Warning:**

- Not adhering to the instructions mentioned in the operating manual may result in life-threatening injuries!
- **GPS** bears no liability for damages or malfunctions resulting from non-compliance with these instructions.

If you have any queries about the technical documentation, please contact us at: [info@gps-stuttgart.de](mailto:info@gps-stuttgart.de)

### 1.2 Note on Using these Operating Instructions

This operating manual includes important details and guidance for various stages of the product's operation:

1. Transport, storage, start of operations and decommissioning.
2. Safe operation, necessary maintenance, and troubleshooting.

The manual describes the product as provided by GPS at the time of delivery. Images are for reference only and may vary based on specific product configurations.



## Fundamental Safety Instructions

### 1. Intended Use

The SICON.PLUG AI VAC is a retrofit system for existing vacuum systems. With the integrated vacuum sensors, pressure profiles can be analysed and compared.

The SICON.PLUG is set up via an APP. To do this, the user must provide information about his vacuum system and the associated data hub, which can be local or in a cloud.

The SICON.PLUG AI VAC is built using the latest technology standards and is shipped securely and safely. However, hazards may occur during operation.

### 2. Non-Intended Use

GPS GmbH bears no liability for direct or indirect losses or damages occurs from the use of the product. This disclaimer applies specifically to any use of the product that deviates from its intended purpose or is not described in this documentation.

### 3. Personnel Qualifications






Unqualified individuals may overlook hazards, which may lead to increased risks!

1. Electrical work and installations may only be handled by qualified electricians.
2. Assembly and adjustment work may only be performed by qualified individuals.

These operating instructions are intended for skilled technicians who are expertise in product handling and installation.

### 4. Signal words in This Document

Warnings alert about potential hazards during product handling. The signal word signifies the level of danger.


Signal word	Meaning
 <b>Danger</b>	High-risk hazard that could cause death or serious injury if not avoided.
 <b>Caution</b>	Low-risk hazard that could cause minor or moderate injury if not avoided.
 <b>Warning</b>	Moderate-risk hazard that could cause death or serious injury if not avoided.
 <b>Info</b>	Important information related to the use of device.
 <b>:note: Note</b>	Additional information or tips to help you use the device.



## 5. Environmental and Operating Conditions

The SICON.PLUG AI VAC must be operated only under the following conditions:

- Temperature range from 0 °C to + 50 °C.
- Maximum relative humidity 90%, non-condensing.

 **Danger:** The product must **not** be operated under an explosive environment. It may lead to an explosion.

In case of doubt, please consult [GPS](#) before operation.

## 6. Technical Condition:

Operating the product while in a defective state may impaired the safety and functionality.

- The product must be operated when in perfect technical condition, i.e., its original state
- Maintenance plan must be followed.
- If there are changes in the operating behaviour, immediately examine the device for faults and address them accordingly.
- If the fault cannot be immediately addressed, switch off the device and label it as defective.
- Any alterations or modifications which are unauthorized, are prohibited.
- Do not make any modifications to the software.

## 7. Operator Responsibilities Regarding Country-Specific Regulations:

Adhere to country-specific regulations concerning accident prevention, safety testing, and environmental protection.

**Product safety note**



Please read the following information carefully. The manufacturer accepts no liability due to improper use of the product.

- Keep the product out of the reach of children.
- Please avoid cleaning the product with excessive use of water.
- Please protect the open ports of the product from water, dust and dirt entrance by appropriate mounting or dust caps.
- Protect the vacuum connections of the product from over pressure.
- The operating voltage must not exceed the maximum values specified in these operating instructions.
- Observe the maximum values of the potential-free contacts, if you use them.





## Introduction

The SICON.PLUG AI VAC is a retrofit system for existing vacuum systems. With the integrated vacuum sensors, pressure profiles can be analysed and compared.

The SICON.PLUG is set up via an APP. To do this, the user must provide information about his vacuum system and the associated data hub, which can be local or in a cloud.

The system automatically sets up during the first 30 minutes and continues to learn during production.

It monitors the state of the system, warns the user of a possible failure and calculates the right time for maintenance in advance.

The operating hours of the system are recorded and the energy consumption is calculated.

An integrated AI function records usage behaviour and offers tips on how to improve or optimize the system's lifetime.

The SICON.PLUG AI VAC detects shocks and impacts on the entire system and informs the user about them. In this way, incorrect operation or failure due to worn parts can be prevented.

The system has a display unit with 3 LEDs, on which the status is visually displayed, in addition, warnings and errors can be reported to a higher-level system via two potential-free contacts.



## Advantages of your SICON.PLUG AI VAC

### Connection

- No additional power supply required as the SICON.PLUG AI VAC can be supplied directly with **24V** industrial standard.
- Network connection via **10 MBIT/s** Ethernet or WLAN according to **IEEE802.11b/g/n** possible.
- High-speed transmission of measured data through modern scalable protocols.
- Easy discrete communication with a **PLC** or instant control of alarms and signalling devices through two dry contacts.

### Industry 4.0 Ready

- Relaxed secure global access to your data by transferring it to the cloud.
- Intelligent user management ensures that each department sees the data that is important to them.
- Simple commissioning via an app.
- Easy configuration of parameters via an internet browser.

### Analytics

- Direct evaluation of your measured data and display via status LEDs using an innovative color concept.
- Predictive maintenance through sophisticated algorithms.
- Messages and notes provide information on where there is still potential for improvement in your vacuum process.
- The revolutionary replay function freezes your process. This allows errors and optimization attempts on the process to be analysed and tested in detail.
- The built-in collision detection generates an error message as soon as, for example, an industrial truck collides with your vacuum system or a rough use has damaged it. This allows you to detect defective or critical machine conditions before they occur.


## Structure of your SICON.PLUG ANALYTICS VAC

### 1.1 Front panel controls




1. **Power LED** indicates whether 24V operating voltage is present at the SICON.PLUG ANALYTICS VAC. If this is the case, the LED lights up green.
2. **Reset button** this allows simple settings to be made directly on the device.
3. **Status bar** with one glance always immediately in view of the status of the machine and the SICON.PLUG ANALYTICS VAC.
4. NFC interface is not supported in the current version.

### 1.2 Controls on the upper side



1. **Vacuum input before the filter** this connection is connected to the system between the vacuum generator and the vacuum filter. The labelling of the connection can also be found on the product label on the back of the plug.
2. **Vacuum input after the filter** this connection is connected to the system between the vacuum filter and the gripper. The labelling of the connection can also be found on the product label on the back of the plug.
3. **WLAN antenna** for wireless connection to the company network.

### 1.3 Controls on the bottom side



1. **5-pin M12x1** plug connection for the supply of the operating voltage and the contact pins of the potential-free contacts.
2. **RJ45 Ethernet** socket for connecting the SICON.PLUG ANALYTICS VAC to the company network.

## 1.4 Status bar

The status bar on the front of the SICON.PLUG ANALYTICS VAC provides information about the current connections. In addition, the current machine status is visualized directly on the device.



### Connection via WLAN

LED	Color	Action	Status
(1)	Blue	shines	Connection via <b>WLAN</b>
	Green	shines	Connection via <b>WLAN</b>

### Connection to IOT Platform

LED	Color	Action	Status
(2)	Green	shines	Connection to <b>IOT platform</b>
	Red	blink	<b>No connection to the IOT platform</b>

### Condition Monitoring

LED	Color	Action	Status
-----	-------	--------	--------

(3)	Green	shines	Machine status <b>L0</b>
	Yellow	shines	Machine status <b>L1</b>
	Orange	shines	Machine status <b>L2</b>
	Red	shines	Machine status <b>L3</b>
	Red	blink	Vacuum sensors are <b>not calibrated</b>
	Yellow	blink	<b>No filter reference value</b> stored in the device

Device Operational States			
LED	Color	Action	Status
All LEDs (1,2,3)	Yellow	shines	The <b>push button</b> of the device is pressed
	Yellow	blink	<b>Reset</b> to the factory settings
	Green	shines	The reference vacuum value was <b>successfully</b> set.
	Red	shines	The <b>reference vacuum value</b> was <b>not</b> successfully set.
	Blue	blink	Ready for <b>registration</b>
	White	blink	The flashing option was selected for <b>identification</b>

## 1.5 Reset Button



The button can be used to reset the SICON.PLUG ANALYTICS VAC to its factory settings. The button can be locked via the software so that you do not have to worry about unintentional operation.

### Warning!

If you lock the button and no longer have access to the device via the software, resetting the device is no longer possible!


Action	Duration	Impact
Push	8s	SICON.PLUG ANALYTICS VAC is reset to the factory settings
Lock	-	Locks the Fast Lane button so that it no longer functions.

## 1.6 NFC interface

The NFC interface is not available in the current version.

## 1.7 Gyroscope and accelerometer

The SICON.PLUG ANALYTICS VAC has a built-in gyroscope and accelerometer. These can be used to measure and display crashes or vibrations that stress the system. The alignment of the sensors is shown in the image below.





## Commissioning

Please follow the instructions for commissioning the device listed here exactly. Damaged devices due to improper commissioning or an unsuitable installation location will not be reimbursed. GPS Stuttgart GmbH accepts no liability for any damage to property or personal injury resulting from improper use of the device.

### 1.8 IT security and port sharing

In order for the plug to communicate with its data broker, it needs the shares listed below within its network. Please ask your IT department to assign these port shares to you. Operation without these shares is not possible. If you have any questions or doubts, please contact a member of GPS Stuttgart GmbH.

Port	Protocol	Direction
<b>OnCloud mode (plug sends data to the cloud)</b>		
80	TCP(HTTP)	Outgoing
1883	TCP(MQTT)	Outgoing
<b>OnSide mode (plug sends data to hardware within the network)</b>		
80	TCP(HTTP)	Bidirectional
1883	TCP(MQTT)	Outgoing

### 1.9 Mounting location


In principle, the SICON.PLUG ANALYTICS VAC can be installed anywhere in your production or logistics environment. It is recommended to mount the SICON.PLUG ANALYTICS VAC in such a way that impacts against the rubber buffers of the system can be detected. Please ensure that the crane system is not damaged or its load-bearing capacity impaired during installation. When mounted in the immediate vicinity, vibration from the pump can be recorded. The maximum recordable vibration here is **25Hz**. However, light impacts against the system can no longer be reliably detected by the motor vibrations.

Please observe the following notes when selecting your installation location:

- Do not install the SICON.PLUG AI VAG in wet environments.
- Protect the device from high mechanical stress.
- Keep the SICON.PLUG AI VAG away from objects that generate a lot of heat.
- Make sure that the mounting location does not have any pronounced magnetic fields, if possible.



## 1.10 Mounting




For the recommended mounting on the support of the vacuum system, you need two **M3** cylinder head screws with hexagon socket and matching washers. First drill two **D=2.5mm** core holes with a borehole spacing of **80mm** at the desired mounting location. Now cut an M3 thread into the two holes. You can then use the two M3 screws to screw the SICON.PLUG ANALYTICS VAC to the support via the slotted holes. The orientation of the SICON.PLUG ANALYTICS VAC is freely selectable, although the variant shown above is recommended.

## 1.11 Hosing

For the pneumatic installation, you will need approved pneumatic hoses with an outer diameter of **6 mm** and pneumatic fittings as required to connect your existing vacuum system to the SICON.PLUG ANALYTICS VAC .

First switch off your vacuum system and make sure that the system is pressure-free. Then connect the left pneumatic connection of the SICON.PLUG ANALYTICS VAC to the vacuum system between the vacuum generator and the vacuum filter. Then connect the right connection to the vacuum system between the vacuum filter and the actuator.

This work should only be carried out by a specialist with sufficient knowledge of pneumatics.



## 1.12 Electrical connection

Work with electrical current should always be carried out by skilled personnel with the necessary training. Please get help if you do not have such training.

The SICON.PLUG ANALYTICS VAC is supplied with **24 V** operating voltage. Please refer to the table below for the corresponding pins.

The two potential-free contacts are based on semiconductor technology, so no mechanical wear stands in the way of an application with many switching cycles. The respective signal branch is switched against the shared pin 5. This can be connected with a voltage up to 30 V or to ground.

**The maximum current must not exceed 750 mA!**

Voltage type	Min.	Typ.	Max.
Operating voltage	19,2 V	24 V	28,8 V
Switching voltage (DC) potential-free contacts	0 V	24 V	30 V



Contact number	Designation	Core color standard actuator cable
1	+24 V	Brown
2	Switch contact 1	White
3	-0 V	Blue
4	Switch contact 2	Black
5	according to connection	Grey or Green

## Important functions

### 1.13 Resetting SICON.PLUG ANALYTICS VAC to factory settings

There are two ways to reset the SICON.PLUG ANALYTICS VAC to its factory settings.

Press and hold the **Reset** button. This will cause the status bar to light up yellow. After approx. **8** seconds, it will start to flash. After a total of **12** seconds, the status bar goes out. When the button is released, the SICON.PLUG ANALYTICS VAC is now reset to its factory settings. If the reset is successful, the status bar pulses blue after a short wait.

The SICON.PLUG ANALYTICS VAC can also be reset very conveniently with the SICON.OS software. To do this, go to the **Assets** program. Then go to the **Settings** of the device to be reset and to the **PARAMETERS** tab. Here you will find the button **restore device parameters to factory defaults**. Click on it. The status bar on the SICON.PLUG now disappears completely. After a few seconds, it pulses blue. The SICON.PLUG ANALYTICS VAC is now reset to its factory defaults.

### 1.14 Calibration of the vacuum sensors

The vacuum sensors of the SICON.PLUG ANALYTICS VAC must be calibrated during initial start-up. This status is indicated by a red flashing **LED 3**. Calibration is performed via the SICON.OS software.

Make sure that no pressure, neither over pressure nor under pressure, is applied to the sensors during the calibration process.

Calibration can be carried out at any time via the software when no pressure is applied. To do this, go to the Assets program. Then go to the **Settings** of the device to be calibrated and click on the **PARAMETERS** tab. Click on the Calibrate Vacuum Sensors button. A successful calibration is visualized by the green illumination of the entire status bar. If calibration fails, the status bar lights up red.

### 1.15 Storing a filter reference value in SICON.PLUG ANALYTICS VAC

For analyses of the filter and the entire vacuum system, it is necessary to store a reference vacuum value in the SICON.PLUG ANALYTICS VAC. A missing reference value is indicated by the yellow flashing of **LED 3**.

Switch on your vacuum generator and ensure that your system can freely draw in air. Now you can store a reference value.

**Warning:**

- This function is always available, please make sure that you do not enter incorrect values.

Via the SICON.OS software you can make the referencing via the Assets program. Click on the settings of the selected device. Now you can store a value by clicking on the button *Teach in a reference vacuum value* which you can find in **PARAMETER**.

## 1.16 Lock reset button

If you want to lock the reset button against unauthorized access or accidental operation, you can do this via the SICON.OS software. To do this, go to the Settings of the device to be locked in the Assets program and to the **PARAMETERS** tab. Select Lock push button in the dropdown list of index **12** and save the settings by clicking on the save icon.

## 1.17 Machine condition level

A deviation of your desired process data can be set via the machine condition level. The normal values of your process should be in the middle of the graphic shown below (**green area**). If your actual value drifts into another range, an event is generated and the **LED3** of the PLUG changes color accordingly. The switching thresholds to another level can be set via the SICON.OS software. To do this, go to the **PARAMETERS** tab in the Assets program. Here you will find all switching thresholds that can be changed in the PLUG.





## Tips and help

### 1.18 Technical data

Technical data	
Manufacturer	GPS GmbH Stuttgart
Operating voltage	24V DC +/- 20%
Rated current	100mA
Dimensions	90mm x 43mm x 26mm with tabs for M3 screws
Weight	300g
LAN interface	10Mbit/s
WLAN interface	IEEE 802.11 b/g/n 2,4GHz

### 1.19 CE conformity and disposal of old equipment

The manufacturer GPS Stuttgart GmbH confirms that the SICON.PLUG ANALYTICS VAC product described in these operating instructions complies with the following relevant EC directives:

**The following harmonized standards have been applied:**

**EN 61000-4-2: 2009** Electromagnetic compatibility - Static electricity discharge

**EN 61000-4-3: 2006** Electromagnetic compatibility - High frequency electromagnetic fields

Please dispose of the product properly after replacement or decommissioning in accordance with the country-specific guidelines and legal obligations for waste prevention.

Housing	Polycarbonate
Seal	TPE
Screws	Steel galvanized
Board	Mixed material plastic metal



## Next steps

- Setting Up via the [SICON.ToolBox App](#).